

# Miska™ ACHD Series Expansion Joint Covers

Expansion Joint  
Cover System

## Maintenance Guide

November, 2019

### ramsetreid recommends the following maintenance program for the Miska™ ACHD Series Expansion Joints

The coverplate must be checked for tension at one (1) year intervals. This is achieved by checking each individual coverplate tensioning screw.

The centre bars inside the expansion joint must be checked for wear at five (5) year intervals. This involves removing the coverplate and inspecting each centring bar for wear or deterioration. Any centre bars showing signs of wear or deterioration must be replaced.

The top surface of the base extrusion of the expansion joint must be kept clean and free of any obstructions or accumulating deposits on a continual basis.

The expansion joint must be checked for deterioration at each side of the joint at one (1) year intervals. This involves checking the grout infill for variations in resonance and sound.

### CLEANING:

Contract Cleaners must use cleaning fluids that contain no harmful chemicals that will result in corroding, discolouring, blemishing or contaminating the structural materials used in the manufacture of the expansion joints.

This awareness must cover Aluminium, Stainless Steel, Zinc Coated steel, and Nylon.

It is recommended that the cleaning contractor consult their cleaning fluid manufacturer for clarification if required.

Where repair work may be required to an existing installation or for further details on the Miska™ range of Expansion Joint Systems offered by ramsetreid, please contact us at:

sales@miska.com.au  
AU: 1300 326 539  
NZ: 0800 88 22 55

